

ANALYTICAL REPORT

Job Number: 420-104634-1

SDG Number: Fallsburg Jr./Sr. High School

Job Description: Sullivan County BOCES

For:

Sullivan County BOCES

6 Weirk Avenue

Liberty, NY 12754

Attention: Jesse Morrill



Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

05/31/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

METHOD SUMMARY

Client: Sullivan County BOCES

Job Number: 420-104634-1
SDG Number: Fallsburg Jr./Sr. High School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Sullivan County BOCES

Job Number: 420-104634-1
SDG Number: Fallsburg Jr./Sr. High School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Sullivan County BOCES

Job Number: 420-104634-1
SDG Number: Fallsburg Jr./Sr. High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-104634-1	302-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-2	302-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-3	302j-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-4	302j-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-5	302G-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-6	302G-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-7	203-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-8	203-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-9	205-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-10	205-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-11	207-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-12	207-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-13	308-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-14	308-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-15	308-S2-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-16	308-S2-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-17	316-D1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-18	316-D1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-19	316-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-20	316-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-21	318-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-22	318-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-23	320-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-24	320-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-25	330A-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-26	330A-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-27	330-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-28	330-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-29	330-D1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-30	330-D1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-31	402-D1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-32	402-D1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-33	404-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-34	404-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-35	401-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-36	401-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-37	403-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-38	403-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-39	405-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-40	405-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-41	416-D1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-42	416-D1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-43	416-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-44	416-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-45	418-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-46	418-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950

SAMPLE SUMMARY

Client: Sullivan County BOCES

Job Number: 420-104634-1
SDG Number: Fallsburg Jr./Sr. High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-104634-47	420-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-48	420-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-49	430-D1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-50	430-D1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-51	430A-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-52	430A-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-53	430-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-54	430-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-55	28-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-56	28-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-57	22-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-58	22-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-59	32C-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-60	32C-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-61	32F-D1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-62	32F-D1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-63	32G-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-64	32G-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-65	32H-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-66	32H-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-67	23-S1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-68	23-S1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-69	23-D1-1	Drinking Water	05/20/2016 0800	05/20/2016 0950
420-104634-70	23-D1-2	Drinking Water	05/20/2016 0800	05/20/2016 0950

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 302-S1-1
Lab Sample ID: 420-104634-1

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/26/2016 0422	
Prep Method: 200			Date Prepared:	05/24/2016 1230	
Pb	7.26	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 302-S1-2
Lab Sample ID: 420-104634-2

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1102		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 302j-S1-1
Lab Sample ID: 420-104634-3

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1105	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	2.96	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 302j-S1-2
Lab Sample ID: 420-104634-4

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1109	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 302G-S1-1
Lab Sample ID: 420-104634-5

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1119	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	8.73	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 302G-S1-2
Lab Sample ID: 420-104634-6

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1123		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 203-S1-1
Lab Sample ID: 420-104634-7

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1126	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	25.6 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 203-S1-2
Lab Sample ID: 420-104634-8

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1130	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.50	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 205-S1-1
Lab Sample ID: 420-104634-9

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1133	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	4.21	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 205-S1-2
Lab Sample ID: 420-104634-10

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1137	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.01	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 207-S1-1
Lab Sample ID: 420-104634-11

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1140	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	6.93	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 207-S1-2
Lab Sample ID: 420-104634-12

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1144	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 308-S1-1
Lab Sample ID: 420-104634-13

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1147	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	6.79	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 308-S1-2
Lab Sample ID: 420-104634-14

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1151		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.95	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 308-S2-1
Lab Sample ID: 420-104634-15

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1201	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	3.00	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 308-S2-2
Lab Sample ID: 420-104634-16

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1205		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 316-D1-1
Lab Sample ID: 420-104634-17

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1208		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 316-D1-2
Lab Sample ID: 420-104634-18

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1212	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 316-S1-1
Lab Sample ID: 420-104634-19

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1215		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 316-S1-2
Lab Sample ID: 420-104634-20

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1229	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.28	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 318-S1-1
Lab Sample ID: 420-104634-21

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1233	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	2.10	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 318-S1-2
Lab Sample ID: 420-104634-22

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1244		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 320-S1-1
Lab Sample ID: 420-104634-23

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1247	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	15.5 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 320-S1-2
Lab Sample ID: 420-104634-24

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1250	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 330A-S1-1
Lab Sample ID: 420-104634-25

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1254	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 330A-S1-2
Lab Sample ID: 420-104634-26

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1258		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 330-S1-1
Lab Sample ID: 420-104634-27

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1301	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	2.15	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 330-S1-2
Lab Sample ID: 420-104634-28

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1305		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 330-D1-1
Lab Sample ID: 420-104634-29

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1308	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 330-D1-2
Lab Sample ID: 420-104634-30

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1312	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 402-D1-1
Lab Sample ID: 420-104634-31

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1315		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 402-D1-2
Lab Sample ID: 420-104634-32

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1326	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	2.26	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 404-S1-1
Lab Sample ID: 420-104634-33

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1329	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.23	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 404-S1-2
Lab Sample ID: 420-104634-34

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1333		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 401-S1-1
Lab Sample ID: 420-104634-35

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1336	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	18.2 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 401-S1-2
Lab Sample ID: 420-104634-36

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1340	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	3.54	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 403-S1-1
Lab Sample ID: 420-104634-37

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1343	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	3.07	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 403-S1-2
Lab Sample ID: 420-104634-38

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1347		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 405-S1-1
Lab Sample ID: 420-104634-39

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1350		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	48.2 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 405-S1-2
Lab Sample ID: 420-104634-40

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1411	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 416-D1-1
Lab Sample ID: 420-104634-41

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1415	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 416-D1-2
Lab Sample ID: 420-104634-42

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1418		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 416-S1-1
Lab Sample ID: 420-104634-43

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1422	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	3.23	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 416-S1-2
Lab Sample ID: 420-104634-44

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1426	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 418-S1-1
Lab Sample ID: 420-104634-45

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1429	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.97	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 418-S1-2
Lab Sample ID: 420-104634-46

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1433	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 420-S1-1
Lab Sample ID: 420-104634-47

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/26/2016 0426		
Prep Method: 200			Date Prepared: 05/24/2016 1230		
Pb	12.7	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 420-S1-2
Lab Sample ID: 420-104634-48

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1436		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 430-D1-1
Lab Sample ID: 420-104634-49

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1440	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.01	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 430-D1-2
Lab Sample ID: 420-104634-50

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1450		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 430A-S1-1
Lab Sample ID: 420-104634-51

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1454		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 430A-S1-2
Lab Sample ID: 420-104634-52

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1457		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 430-S1-1
Lab Sample ID: 420-104634-53

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1501		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 430-S1-2
Lab Sample ID: 420-104634-54

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1504		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 28-S1-1
Lab Sample ID: 420-104634-55

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1508	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	3.15	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 28-S1-2
Lab Sample ID: 420-104634-56

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1511		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 22-S1-1
Lab Sample ID: 420-104634-57

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1515		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 22-S1-2
Lab Sample ID: 420-104634-58

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1519	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 32C-S1-1
Lab Sample ID: 420-104634-59

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1522	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.60	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 32C-S1-2
Lab Sample ID: 420-104634-60

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1533	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.15	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 32F-D1-1
Lab Sample ID: 420-104634-61

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/25/2016 1547		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 32F-D1-2
Lab Sample ID: 420-104634-62

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1550	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 32G-S1-1
Lab Sample ID: 420-104634-63

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1554	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	2.66	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 32G-S1-2
Lab Sample ID: 420-104634-64

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1557	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 32H-S1-1
Lab Sample ID: 420-104634-65

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1601	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.19	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 32H-S1-2
Lab Sample ID: 420-104634-66

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/25/2016 1605	
Prep Method: 200			Date Prepared:	05/24/2016 1100	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 23-S1-1
Lab Sample ID: 420-104634-67

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/27/2016 0116		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	29.6 g	ug/L	2.00	2.00	2.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 23-S1-2
Lab Sample ID: 420-104634-68

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/27/2016 0119		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 23-D1-1
Lab Sample ID: 420-104634-69

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/27/2016 0123		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-104634-1
Sdg Number: Fallsburg Jr./Sr. High School

Client Sample ID: 23-D1-2
Lab Sample ID: 420-104634-70

Date Sampled: 05/20/2016 0800
Date Received: 05/20/2016 0950
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 05/27/2016 0127		
Prep Method: 200			Date Prepared: 05/24/2016 1100		
Pb	1.00 U	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Sullivan County BOCES

Job Number:
Sdg Number: Fallsburg Jr./Sr. High School

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Definitions and Glossary

Client: Sullivan County BOCES

Job Number:

Sdg Number: Fallsburg Jr./Sr. High School

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.



EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

104634

315 Fullerton Avenue
Newburgh, NY 12550
TEL (845) 562-0890
FAX (845) 562-0841

CUSTOMER SCBOCES
ADDRESS 6 Wicks Ave.
CITY/STATE Liberty NY
ZIP 1245 PHONE 549-0682
CONTACT Sease Merrill
PROJECT Williamsburg Sr/HS High School
LOCATION Williamsburg Sr/HS High School
PRJ NUMBER/P.O.#

REPORT TYPE

STANDARD ISRA FURNAROUND

NJ REG QUICK

NYASP A B VERBAL

OTHER

MATRIX: DW=DRINKING WATER S=SOIL O=OIL WW=WASTE WATER
SL=SLUDGE GW=GROUND WATER

Sample # DATE SAMPLING TIME GRAB (Y/N) MATRIX Client I.D.

Sample #	DATE	SAMPLING TIME	GRAB (Y/N)	MATRIX	Client I.D.	Total # of containers	ANALYSIS REQUESTED
1	302-51-2	5/16/16 0800		DW	See "Sample #"	40ml Glass HCL Liter Glass HCL 250ml Amber H2SO4 Liter Amber Plain 250ml Plastic HNO3 250ml Plastic NaOH Liter Plastic Liter Plastic H2SO4 250ml Plastic 125ml Plastic Sterile 8oz Glass 2oz Glass 250ml Pl. NaOH/ZnAcc	NY PUBLIC WATER SUPPLIES SOURCE ID ELRP TYPE FEDERAL ID
2	302-51-2						Lead
3	302-51-1						
4	302-51-2						
5	302-51-1						
6	302-51-2						
7	302-51-1						
8	302-51-2						
9	302-51-1						
10	302-51-2						
11	302-51-1						
12	302-51-2						

SAMPLES SUBMITTED FOR ANALYSIS WILL BE SUBJECT TO THE ENVIROTEST TERMS AND CONDITIONS OF SALE (SHORT FORM) UNLESS ALTERNATE TERMS ARE AGREED IN WRITING.

RELINQUISHED BY: [Signature] COMPANY: SCBOCES DATE: 5/16/16 TIME: 8:05
RECEIVED BY: [Signature] COMPANY: ETL DATE: 5-20-16 TIME: 0950

SAMPLED BY: [Signature] COMPANY: SCBOCES DATE: 5/16/16 TIME: 8:05
ANALYZED BY: [Signature] COMPANY: ETL DATE: 5-20-16 TIME: 0950

COMMENTS: [Blank]

NYS DOH 10142 NIDEP NY015 CTDOH PH-0554 EPA NY00049

1/3

104634

a/3

	Sample #	Date	Time	Matrix	Client ID	250 ml HNO3	Analysis Requested
13	308-S1-1	5/20/16	0950				
14	308-S1-2						
15	308-S2-1						
16	308-S2-2						
17	316-D1-1						
18	316-D1-2						
19	316-S1-1						
20	316-S1-2						
21	318-S1-1						
22	318-S1-2						
23	320-S1-1						
24	320-S1-2						
25	330A-S1-1						
26	330A-S1-2						
27	330-S1-1						
28	330-S1-2						
29	330-D1-1						
30	330-D1-2						
31	402-D1-1						
32	402-D1-2						
33	404-S1-1						
34	404-S1-2						
35	401-S1-1						
36	401-S1-2						
37	403-S1-1						
38	403-S1-2						
39	405-S1-1						
40	405-S1-2						
41	416-D1-1						
42	416-D1-2						
43	416-S1-1						
44	416-S1-2						
45	418-S1-1						
46	418-S1-2						
47	420-S1-1						
48	420-S1-2						
49	430-D1-1						
50	430-D1-2						
51	430A-S1-1						
52	430A-S1-2						
53	430-S1-1						
54	430-S1-2						
55	28-S1-1						
56	28-S1-2						

R.J.C. ROBERT J. LAFAYETTE CSArch 5.20.16 9:50
 a Elmendorf ETL 5/20/16 0950 18.40C on ice

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Sullivan County BOCES

Job Number: 420-104634-1
SDG Number: Fallsburg Jr./Sr. High School

Login Number: 104634

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is recorded.	True	18.4 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	True	
Based on above criteria cooler temperature is acceptable.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	