

ANALYTICAL REPORT

Job Number: 420-111451-1
SDG Number: Fallsburgh Jr/Sr. High School
Job Description: Sullivan County BOCES

For:
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Attention: Jesse Morrill



Meredith W Ruthven
Customer Service Manager
mruthven@envirotestlaboratories.com
11/07/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

METHOD SUMMARY

Client: Sullivan County BOCES

Job Number: 420-111451-1
SDG Number: Fallsburgh Jr/Sr. High School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Sullivan County BOCES

Job Number: 420-111451-1
SDG Number: Fallsburgh Jr/Sr. High School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Palentino, Gus J	GJP
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Sullivan County BOCES

Job Number: 420-111451-1
SDG Number: Fallsburgh Jr/Sr. High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-111451-1	007-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-2	007-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-3	011-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-4	011-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-5	012-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-6	012-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-7	012-S3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-8	012-S4	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-9	GLR-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-10	GLR-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-11	BLR-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-12	BLR-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-13	023-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-14	023-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-15	023-S3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-16	101-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-17	101-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-18	104-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-19	104-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-20	107-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-21	107-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-22	107-S3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-23	107-S4	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-24	107-S5	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-25	GGLR-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-26	GGLR-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-27	GGLR-S3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-28	BGLR-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-29	BGLR-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-30	BGLR-S3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-31	203-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-32	203-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-33	203-S3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-34	203-S4	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-35	203-S5	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-36	203-S6	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-37	203-S7	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-38	203-S8	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-39	203-S9	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-40	203-S10	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-41	207-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-42	207-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-43	207-S3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-44	207-S4	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-45	211-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-46	211-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506

SAMPLE SUMMARY

Client: Sullivan County BOCES

Job Number: 420-111451-1
SDG Number: Fallsburgh Jr/Sr. High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-111451-47	213-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-48	213-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-49	308-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-50	308-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-51	316-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-52	316-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-53	316-S3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-54	318-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-55	318-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-56	318-S3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-57	401-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-58	401-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-59	401-S3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-60	401-S4	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-61	401-S5	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-62	401-S6	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-63	401-S7	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-64	401-S8	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-65	401-S9	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-66	401-S10	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-67	405-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-68	405-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-69	405-S3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-70	405-S4	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-71	405-S5	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-72	405-S6	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-73	405-S7	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-74	405-S8	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-75	405-S9	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-76	405-S10	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-77	405-S11	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-78	405-S12	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-79	405-S13	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-80	405-S14	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-81	405-S15	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-82	405-S16	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-83	416-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-84	416-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-85	416-S3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-86	418-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-87	418-S2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-88	418-S3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-89	HB-1	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-90	HB-2	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-91	HB-3	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-92	KIT-HW	Drinking Water	10/06/2016 0600	10/06/2016 1506

SAMPLE SUMMARY

Client: Sullivan County BOCES

Job Number: 420-111451-1
SDG Number: Fallsburgh Jr/Sr. High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-111451-93	KIT-DW	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-94	109-ICE	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-95	105-ICE	Drinking Water	10/06/2016 0600	10/06/2016 1506
420-111451-96	320-S1	Drinking Water	10/06/2016 0600	10/06/2016 1506

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 007-S1
Lab Sample ID: 420-111451-1

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	11/01/2016 1244	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	3.36	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 007-S2
Lab Sample ID: 420-111451-2

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1605	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	2.51	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 011-S1
Lab Sample ID: 420-111451-3

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1613	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	4.24	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 011-S2
Lab Sample ID: 420-111451-4

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1615		
Prep Method: 200			Date Prepared: 10/31/2016 0900		
Pb	1.10	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 012-S1
Lab Sample ID: 420-111451-5

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1616		
Prep Method: 200			Date Prepared: 10/31/2016 0900		
Pb	30.1 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 012-S2
Lab Sample ID: 420-111451-6

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1622	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	4.05	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 012-S3
Lab Sample ID: 420-111451-7

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1624	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	6.94	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 012-S4
Lab Sample ID: 420-111451-8

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1626	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	3.33	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: GLR-S1
Lab Sample ID: 420-111451-9

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1628	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	12.1	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: GLR-S2
Lab Sample ID: 420-111451-10

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1629	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	4.41	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: BLR-S1
Lab Sample ID: 420-111451-11

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1631	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	1.43	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: BLR-S2
Lab Sample ID: 420-111451-12

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1633	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	1.58	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 023-S1
Lab Sample ID: 420-111451-13

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1635	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	19.3 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 023-S2
Lab Sample ID: 420-111451-14

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1637	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	9.96	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 023-S3
Lab Sample ID: 420-111451-15

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1639	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	15.3 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 101-S1
Lab Sample ID: 420-111451-16

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1644	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 101-S2
Lab Sample ID: 420-111451-17

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1646	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 104-S1
Lab Sample ID: 420-111451-18

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1648		
Prep Method: 200			Date Prepared: 10/31/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 104-S2
Lab Sample ID: 420-111451-19

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1650		
Prep Method: 200			Date Prepared: 10/31/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 107-S1
Lab Sample ID: 420-111451-20

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1652		
Prep Method: 200			Date Prepared: 10/31/2016 0900		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 107-S2
Lab Sample ID: 420-111451-21

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1654	
Prep Method: 200			Date Prepared:	10/31/2016 0900	
Pb	3.44	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 107-S3
Lab Sample ID: 420-111451-22

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1656	
Prep Method: 200			Date Prepared:	10/31/2016 0955	
Pb	4.42	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 107-S4
Lab Sample ID: 420-111451-23

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1707	
Prep Method: 200			Date Prepared:	10/31/2016 0955	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 107-S5
Lab Sample ID: 420-111451-24

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1709	
Prep Method: 200			Date Prepared:	10/31/2016 0955	
Pb	2.63	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: GGLR-S1
Lab Sample ID: 420-111451-25

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1711	
Prep Method: 200			Date Prepared:	10/31/2016 0955	
Pb	2.94	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: GGLR-S2
Lab Sample ID: 420-111451-26

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1712		
Prep Method: 200			Date Prepared: 10/31/2016 0955		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: GGLR-S3
Lab Sample ID: 420-111451-27

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1714		
Prep Method: 200			Date Prepared: 10/31/2016 0955		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: BGLR-S1
Lab Sample ID: 420-111451-28

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1716	
Prep Method: 200			Date Prepared:	10/31/2016 0955	
Pb	2.38	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: BGLR-S2
Lab Sample ID: 420-111451-29

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1718		
Prep Method: 200			Date Prepared: 10/31/2016 0955		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: BGLR-S3
Lab Sample ID: 420-111451-30

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1720		
Prep Method: 200			Date Prepared: 10/31/2016 0955		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 203-S1
Lab Sample ID: 420-111451-31

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1722	
Prep Method: 200			Date Prepared:	10/31/2016 0955	
Pb	26.2 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 203-S2
Lab Sample ID: 420-111451-32

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1724		
Prep Method: 200			Date Prepared: 10/31/2016 0955		
Pb	17.3 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 203-S3
Lab Sample ID: 420-111451-33

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1729	
Prep Method: 200			Date Prepared:	10/31/2016 0955	
Pb	24.0 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 203-S4
Lab Sample ID: 420-111451-34

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1731	
Prep Method: 200			Date Prepared:	10/31/2016 0955	
Pb	42.4 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 203-S5
Lab Sample ID: 420-111451-35

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1733	
Prep Method: 200			Date Prepared:	10/31/2016 0955	
Pb	36.9 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 203-S6
Lab Sample ID: 420-111451-36

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1735		
Prep Method: 200			Date Prepared: 10/31/2016 0955		
Pb	75.9 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 203-S7
Lab Sample ID: 420-111451-37

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1737		
Prep Method: 200			Date Prepared: 10/31/2016 0955		
Pb	15.6 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 203-S8
Lab Sample ID: 420-111451-38

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1739	
Prep Method: 200			Date Prepared:	10/31/2016 0955	
Pb	50.8 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 203-S9
Lab Sample ID: 420-111451-39

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1741		
Prep Method: 200			Date Prepared: 10/31/2016 0955		
Pb	20.1 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 203-S10
Lab Sample ID: 420-111451-40

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1742		
Prep Method: 200			Date Prepared: 10/31/2016 0955		
Pb	18.1 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 207-S1
Lab Sample ID: 420-111451-41

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1744	
Prep Method: 200			Date Prepared:	10/31/2016 0955	
Pb	14.0	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 207-S2
Lab Sample ID: 420-111451-42

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1746	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	6.22	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 207-S3
Lab Sample ID: 420-111451-43

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1758	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	10.7	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 207-S4
Lab Sample ID: 420-111451-44

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1759	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	4.38	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 211-S1
Lab Sample ID: 420-111451-45

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1801		
Prep Method: 200			Date Prepared: 10/31/2016 1000		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 211-S2
Lab Sample ID: 420-111451-46

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1803	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 213-S1
Lab Sample ID: 420-111451-47

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1805		
Prep Method: 200			Date Prepared: 10/31/2016 1000		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 213-S2
Lab Sample ID: 420-111451-48

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1807		
Prep Method: 200			Date Prepared: 10/31/2016 1000		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 308-S1
Lab Sample ID: 420-111451-49

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1809	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	3.23	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 308-S2
Lab Sample ID: 420-111451-50

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1815		
Prep Method: 200			Date Prepared: 10/31/2016 1000		
Pb	32.7 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 316-S1
Lab Sample ID: 420-111451-51

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1817	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	3.06	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 316-S2
Lab Sample ID: 420-111451-52

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1818	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	1.47	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 316-S3
Lab Sample ID: 420-111451-53

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1820	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	3.12	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 318-S1
Lab Sample ID: 420-111451-54

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1822	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	4.18	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 318-S2
Lab Sample ID: 420-111451-55

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1824	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	4.23	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 318-S3
Lab Sample ID: 420-111451-56

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1826	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	106 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 401-S1
Lab Sample ID: 420-111451-57

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1828	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	29.6 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 401-S2
Lab Sample ID: 420-111451-58

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1830	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	18.7 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 401-S3
Lab Sample ID: 420-111451-59

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1832	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	8.07	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 401-S4
Lab Sample ID: 420-111451-60

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1837	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	9.92	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 401-S5
Lab Sample ID: 420-111451-61

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1839	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	23.1 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 401-S6
Lab Sample ID: 420-111451-62

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1841	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	48.8 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 401-S7
Lab Sample ID: 420-111451-63

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1849	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	4.71	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 401-S8
Lab Sample ID: 420-111451-64

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1851	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	26.2 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 401-S9
Lab Sample ID: 420-111451-65

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1853	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	46.1 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 401-S10
Lab Sample ID: 420-111451-66

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1855	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	30.5 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S1
Lab Sample ID: 420-111451-67

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1900	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	121 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S2
Lab Sample ID: 420-111451-68

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1902	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	219 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S3
Lab Sample ID: 420-111451-69

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1904	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	77.9 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S4
Lab Sample ID: 420-111451-70

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1906	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	117 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S5
Lab Sample ID: 420-111451-71

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1908	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	19.9 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S6
Lab Sample ID: 420-111451-72

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1910	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	2.82	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S7
Lab Sample ID: 420-111451-73

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1912	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	26.0 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S8
Lab Sample ID: 420-111451-74

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1914	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	47.4 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S9
Lab Sample ID: 420-111451-75

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1915	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	29.8 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S10
Lab Sample ID: 420-111451-76

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1917	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	18.6 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S11
Lab Sample ID: 420-111451-77

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1923	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	23.8 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S12
Lab Sample ID: 420-111451-78

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1925	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	16.3 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S13
Lab Sample ID: 420-111451-79

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1927	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	35.7 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S14
Lab Sample ID: 420-111451-80

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1929	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	18.1 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S15
Lab Sample ID: 420-111451-81

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1931	
Prep Method: 200			Date Prepared:	10/31/2016 1000	
Pb	47.5 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 405-S16
Lab Sample ID: 420-111451-82

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1933		
Prep Method: 200			Date Prepared: 10/31/2016 1030		
Pb	156 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 416-S1
Lab Sample ID: 420-111451-83

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1940	
Prep Method: 200			Date Prepared:	10/31/2016 1030	
Pb	12.0	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 416-S2
Lab Sample ID: 420-111451-84

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1946	
Prep Method: 200			Date Prepared:	10/31/2016 1030	
Pb	3.73	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 416-S3
Lab Sample ID: 420-111451-85

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1948	
Prep Method: 200			Date Prepared:	10/31/2016 1030	
Pb	1.92	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 418-S1
Lab Sample ID: 420-111451-86

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1950	
Prep Method: 200			Date Prepared:	10/31/2016 1030	
Pb	1.22	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 418-S2
Lab Sample ID: 420-111451-87

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1607	
Prep Method: 200			Date Prepared:	10/31/2016 1030	
Pb	2.22	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 418-S3
Lab Sample ID: 420-111451-88

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1608	
Prep Method: 200			Date Prepared:	10/31/2016 1030	
Pb	7.45	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: HB-1
Lab Sample ID: 420-111451-89

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1608	
Prep Method: 200			Date Prepared:	10/31/2016 1030	
Pb	6.78	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: HB-2
Lab Sample ID: 420-111451-90

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1609	
Prep Method: 200			Date Prepared:	10/31/2016 1030	
Pb	36.2 g	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: HB-3
Lab Sample ID: 420-111451-91

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1610	
Prep Method: 200			Date Prepared:	10/31/2016 1030	
Pb	2.72	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: KIT-HW
Lab Sample ID: 420-111451-92

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/31/2016 1611	
Prep Method: 200			Date Prepared:	10/31/2016 1030	
Pb	2.31	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: KIT-DW
Lab Sample ID: 420-111451-93

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1611		
Prep Method: 200			Date Prepared: 10/31/2016 1030		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 109-ICE
Lab Sample ID: 420-111451-94

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1612		
Prep Method: 200			Date Prepared: 10/31/2016 1030		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 105-ICE
Lab Sample ID: 420-111451-95

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1613		
Prep Method: 200			Date Prepared: 10/31/2016 1030		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jesse Morrill
Sullivan County BOCES
6 Weirk Avenue
Liberty, NY 12754

Job Number: 420-111451-1
Sdg Number: Fallsburgh Jr/Sr. High School

Client Sample ID: 320-S1
Lab Sample ID: 420-111451-96

Date Sampled: 10/06/2016 0600
Date Received: 10/06/2016 1506
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 10/31/2016 1614		
Prep Method: 200			Date Prepared: 10/31/2016 1030		
Pb	18.9 g	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Sullivan County BOCES

Job Number:
Sdg Number: Fallsburgh Jr/Sr. High School

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Sullivan County BOCES

Job Number:

Sdg Number: Fallsburgh Jr/Sr. High School

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalein Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Sullivan County BOCES

Job Number:

Sdg Number: Fallsburgh Jr/Sr. High School

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

111451

1 of 3

water samples

	Sample #	Date	Time	AREA	250 ml HNO3	Analysis Requested
1	007-S1	10/6/16	6am	LEFT SINK		LEAD
2	007-S2			RIGHT SINK		
3	011-S1			LEFT SINK		
4	011-S2			RIGHT SINK		
5	012-S1			LEFT FIXTURE		
6	012-S2			MIDDLE LEFT FIXTURE		
7	012-S3			MIDDLE RIGHT FIXTURE		
8	012-S4			RIGHT FIXTURE		
9	GLR-S1			LEFT SINK		
10	GLR-S2			RIGHT SINK		
11	BLR-S1			LEFT SINK		
12	BLR-S2			RIGHT SINK		
13	023-S1			LEFT SINK		
14	023-S2			RIGHT SINK		
15	023-S3			SINGLE SINK		
16	101-S1			LEFT SINK		
17	101-S2			RIGHT SINK		
18	104-S1			LEFT SINK		
19	104-S2			RIGHT SINK		
20	107-S1			LEFT SINK		
21	107-S2			MIDDLE LEFT SINK		
22	107-S3			MIDDLE SINK		
23	107-S4			MIDDLE RIGHT SINK		
24	107-S5			RIGHT SINK		
25	GGLR-S1			COACHES OFFICE SINK		
26	GGLR-S2			LEFT SINK		
27	GGLR-S3			RIGHT SINK		
28	BGLR-S1			COACHES OFFICE SINK		
29	BGLR-S2			LEFT SINK		
30	BGLR-S3			RIGHT SINK		
31	203-S1			TEACHERS DECK SINK		
32	203-S2			LEFT SINK - WINDOW		
33	203-S3			LEFT SINK		
34	203-S4			MIDDLE LEFT SINK- WINDOW		
35	203-S5			MIDDLE LEFT SINK		
36	203-S6			MIDDLE RIGHT SINK- WINDOW		
37	203-S7			MIDDLE RIGHT SINK		
38	203-S8			RIGHT SINK- WINDOW		
39	203-S9			RIGHT SINK		
40	203-S10			RIGHT SINGLE		
41	207-S1			LEFT SINK		
42	207-S2			MIDDLE LEFT SINK		
43	207-S3			MIDDLE RIGHT SINK		
44	207-S4			RIGHT SINK		

Relinquished By: *[Signature]* 1506 10/6/16

Received by: *[Signature]* 1506 10/6/16 23.0°C NOICE R#3

11451

2 of 3

water samples

45	211-S1		LEFT SINK		
46	211-S2		RIGHT SINK		
47	213-S1		LEFT SINK		
48	213-S2		RIGHT SINK		
49	308-S1		BATHROOM SINK		
50	308-S2		SINGLE SINK		
51	316-S1		LEFT SINK		
52	316-S2		MIDDLE SINK		
53	316-S3		RIGHT SINK		
54	318-S1		LEFT SINK		
55	318-S2		MIDDLE SINK		
56	318-S3		RIGHT SINK		
57	401-S1		LEFT SINK- WINDOW		
58	401-S2		LEFT SINK		
59	401-S3		MIDDLE LEFT SINK- WINDOW		
60	401-S4		MIDDLE LEFT SINK		
61	401-S5		MIDDLE SINK- WINDOW		
62	401-S6		MIDDLE SINK		
63	401-S7		MIDDLE RIGHT SINK- WINDOW		
64	401-S8		MIDDLE RIGHT SINK		
65	401-S9		RIGHT SINK- WINDOW		
66	401-S10		RIGHT SINK		
67	405-S1		See map		
68	405-S2		See map		
69	405-S3		See map		
70	405-S4		See map		
71	405-S5		See map		
72	405-S6		See map		
73	405-S7		See map		
74	405-S8		See map		
75	405-S9		See map		
76	405-S10		See map		
77	405-S11		See map		
78	405-S12		See map		
79	405-S13		See map		
80	405-S14		See map		
81	405-S15		See map		
82	405-S16		See map		
83	416-S1		LEFT SINK		
84	416-S2		MIDDLE SINK		
85	416-S3		RIGHT SINK		
86	418-S1		LEFT SINK		
87	418-S2		MIDDLE SINK		
88	418-S3		RIGHT SINK		
89	HB-1		NEAR BUSINESS OFFICE		
90	HB-2		NEAR GIRLS L.R. TENNIS COURT		

Relinquished By: *[Signature]* 1506 10/6/16

Received by: *[Signature]* 1506 10/6/16 23.0°C NOICE R#3

111451

water samples

91	HB-3			UNDER OVERHANG		
92	KIT-HW			KITCHEN HANDWASH SINK		
93	KIT-DW			KITCHEN DISHWASH SINK		
94	109-ICE			ICE MAKER		
95	105-ICE			ICE MAKER		
96	320-S1					

Relinquished By *[Signature]* 1506 10/6/16

Received by: *[Signature]* 1506 10/6/16 23.0 °C
NO ICE
12/13

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Sullivan County BOCES

Job Number: 420-111451-1
SDG Number: Fallsburgh Jr/Sr. High School

Login Number: 111451

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	23.0 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	